

600 SERIES SLIDING GLASS DOOR

TEST REPORT SUMMARY

In compliance to AAMA/
101/I.S.2/ CSA A440

TEST SIZE	1816mm x 2025mm
	71 1/2" x 79 3/4"

STANDARD	REQUIREMENTS		RESULTS	GRADE	
	TEST METHOD	TEST PRESSURE		AAMA	CSA
Air Tightness	ASTM E 283	+@ 75 Pascals +@ 1.57 psf	0.30 L/s.m ²	A3	A3
			+/-0.06 CFM/ft ²		
Water Tightness	ASTM E 547	@ 335 Pascals @ 7 psf	No Leakage	DP 45	B3
Wind Load Resistance	ASTM E 330	+@ 3375 Pa @ 70 psf	No Deformation	DP 45	C3
Series 600 sliding glass door is rated SD-R-45, Design Pressure 45 @ test pressure 266 kph (166 mph).					

Note: The reader is cautioned that test results should be used for comparison purposes only. Results are size and installation dependent. In-Service performance can be significantly different from those shown.

© Copyright Inline Fiberglass Ltd. of Toronto, Canada 2010.